

PORTABLE APPLIANCE TESTING REPORT

LDJ Events - 07891 380805 Mobile Disco & Karaoke, Lighting & Sound, Party Photography				REPORT NO: June_2018_001			LDJ Events Telford, Shropshire TF2 6SJ		
PAT Engineer: <i>Layton Chantry</i> Certificate Date: <i>13th March 2017</i> Certificate Number: <i>BJQ378-4</i>				DATE: 01/06/2018					
ID NO.	APPLIANCE DESCRIPTION	CLASS	VISUAL INSPECT	TEST					
				Continuity Ohms	Ins Mohms	Leak (mA)			
001	Equinox Micropar	2	Pass	N/A	>99.99	0.10	Jul19	PASS	
002	Equinox Micropar	2	Pass	N/A	>99.99	0.10	Jul19	PASS	
003	Equinox Micropar	2	Pass	N/A	>99.99	0.10	Jul19	PASS	
004	Equinox Micropar	2	Pass	N/A	>99.99	0.10	Jul19	PASS	
005	Ext Lead	1	Pass	0.06	>99.99	N/A	Jul19	PASS	
006	Ext Lead	1	Pass	0.04	>99.99	N/A	Jul19	PASS	
007	Equinox Interceptor	1	Pass	0.10	>99.99	0.24	Jul19	PASS	
008	Ibiza 9	2	Pass	N/A	>99.99	0.24	Jul19	PASS	
009	IEC Lead	1	Pass	0.04	>99.99	N/A	Jul19	PASS	
010	Ext Lead	1	Pass	0.16	>99.99	N/A	Jul19	PASS	
011	Ext Lead	1	Pass	0.07	>99.99	N/A	Jul19	PASS	
012	Ext Lead	1	Pass	0.07	>99.99	N/A	Jul19	PASS	
013	IEC Lead	1	Pass	0.07	>99.99	N/A	Jul19	PASS	
014	IEC Lead	1	Pass	0.19	>99.99	N/A	Jul19	PASS	
015	Ext Lead	1	Pass	0.03	>99.99	N/A	Jul19	PASS	
016	Ext Lead	1	Pass	0.06	>99.99	N/A	Jul19	PASS	
017	Ext Lead	1	Pass	0.06	>99.99	N/A	Jul19	PASS	
018	Ext Lead	1	Pass	0.09	>99.99	N/A	Jul19	PASS	
019	IEC Lead	1	Pass	0.02	>99.99	N/A	Jul19	PASS	
020	IEC Lead	1	Pass	0.04	>99.99	N/A	Jul19	PASS	

ID NO.	APPLIANCE DESCRIPTION	CLASS	VISUAL INSPECT	TEST			DATE OF NEXT TEST	PASS or FAIL	COMMENTS
				Continuity	Ins	Leak			
				Ohms	Mohms	(mA)			
021	IEC Lead	1	Pass	0.09	>99.99	N/A	Jul19	PASS	
022	IEC Lead	1	Pass	0.08	>99.99	N/A	Jul19	PASS	
023	Ext Lead	1	Pass	0.08	>99.99	N/A	Jul19	PASS	
024	Ext Lead	1	Pass	0.15	>99.99	N/A	Jul19	PASS	
025	IEC Lead	1	Pass	0.03	>99.99	N/A	Jul19	PASS	
026	IEC - 13amp	1	Pass	0.09	>99.99	N/A	Jul19	PASS	
027	IEC Lead	1	Pass	0.07	>99.99	N/A	Jul19	PASS	
028	IEC Ext	1	Pass	0.06	>99.99	N/A	Jul19	PASS	
029	IEC Ext	1	Pass	0.05	>99.99	N/A	Jul19	PASS	
030	IEC Lead	1	Pass	0.09	>99.99	N/A	Jul19	PASS	
031	IEC Lead	1	Pass	0.04	>99.99	N/A	Jul19	PASS	
032	IEC Ext	1	Pass	0.08	>99.99	N/A	Jul19	PASS	
033	Neo-Neon Party Bar	1	Pass	0.10	>99.99	0.10	Jul19	PASS	
034	Neo-Neon Party Bar	1	Pass	0.05	>99.99	0.11	Jul19	PASS	
035	KAM LED UV Bar	1	Pass	0.06	>99.99	0.10	Jul19	PASS	
036	Equinox LED Bar	1	Pass	0.05	>99.99	0.10	Jul19	PASS	
037	Equinox LED Bar	1	Pass	0.04	>99.99	0.10	Jul19	PASS	
038	ADJ Inno Pocket Spot	2	Pass	N/A	>99.99	0.24	Jul19	PASS	
039	ADJ Inno Pocket Spot	2	Pass	N/A	>99.99	0.24	Jul19	PASS	
040	ADJ Mega Tri Par Profile	2	Pass	N/A	>99.99	0.18	Jul19	PASS	
041	ADJ Mega Tri Par Profile	2	Pass	N/A	>99.99	0.16	Jul19	PASS	
042	KAM iLink Laser	1	Pass	0.05	>99.99	0.1	Jul19	PASS	
043	Equinox TriClops	1	Pass	0.05	>99.99	0.10	Jul19	PASS	
044	Equinox TriClops	1	Pass	0.05	>99.99	0.22	Jul19	PASS	
045	IEC Lead	1	Pass	0.03	>99.99	N/A	Jul19	PASS	
046	Equinox Gobo Projector	1	Pass	0.07	>99.99	0.26	Jul19	PASS	
047	KAM Smoke Machine	1	Pass	0.20	2.02	0.13	Jul19	PASS	

ID NO.	APPLIANCE DESCRIPTION	CLASS	VISUAL INSPECT	TEST			DATE OF NEXT TEST	PASS or FAIL	COMMENTS
				Continuity	Ins	Leak			
				Ohms	Mohms	(mA)			
048	Alto Mixer	2	Pass	N/A	>99.99	0.10	Jul19	PASS	
049	Prosound Radio Mic	2	Pass	N/A	>99.99	0.18	Jul19	PASS	
050	PC Monitor	2	Pass	N/A	>99.99	0.18	Jul19	PASS	
051	Equinox Quadzilla	1	Pass	N/A	>99.99	0.10	Jul19	PASS	
052	Alto 800w Active Speaker	2	Pass	N/A	>99.99	0.10	Jul19	PASS	
053	Alto 800w Active Speaker	2	Pass	N/A	>99.99	1.11	Jul19	PASS	
054	Alto 1100w Active Speaker	2	Pass	N/A	>99.99	0.10	Jul19	PASS	
055	Alto 1100w Active Speaker	2	Pass	N/A	>99.99	0.10	Jul19	PASS	
056	Yamaha DXR15 Active Speaker	1	Pass	0.12	>99.99	0.43	Jul19	PASS	
057	Yamaha DXR15 Active Speaker	1	Pass	0.12	>99.99	0.33	Jul19	PASS	
058	Chauvet Obey 10 DMX Controller	2	Pass	N/A	>99.99	0.10	Jul19	PASS	
059	Alto Radius 100 Radio Mic Kit	2	Pass	N/A	>99.99	0.11	Jul19	PASS	
060	Numark CD Mixer	1	Pass	0.07	>99.99	0.12	Jul19	PASS	
061	Ext Lead	1	Pass	0.08	>99.99	N/A	Jul19	PASS	
062	Showtec LED OP1	2	Pass	N/A	>99.99	0.1	Jul19	PASS	
063	TV	2	Pass	N/A	>99.99	0.10	Jul19	PASS	
064	TV	2	Pass	N/A	>99.99	0.10	Jul19	PASS	
065	Apple Mac Charger	2	Pass	N/A	>99.99	0.10	Jul19	PASS	
066	Yoga Charger	2	Pass	N/A	49.47	0.10	Jul19	PASS	
067	Ext Lead	1	Pass	0.14	>99.99	N/A	Jul19	PASS	
068	Photography Lighting	1	Pass	0.07	>99.99	0.11	Jul19	PASS	
069	Photography Lighting	1	Pass	0.06	>99.99	0.10	Jul19	PASS	
070	Samson XP308i PA System	2	Pass	N/A	>99.99	0.11	Jul19	PASS	
071	IEC Lead	1	Pass	0.08	>99.99	N/A	Jul19	PASS	
072	ADJ Inno Pocket Roll	2	Pass	N/A	>99.99	0.24	Jul19	PASS	
073	Chauvet Stinger Mk2	2	Pass	N/A	>99.99	0.15	Jul19	PASS	
074	ADJ Inno Pocket Roll	2	Pass	N/A	>99.99	0.24	Jul19	PASS	

ID NO.	APPLIANCE DESCRIPTION	CLASS	VISUAL INSPECT	TEST			DATE OF NEXT TEST	PASS or FAIL	COMMENTS
				Continuity	Ins	Leak			
				Ohms	Mohms	(mA)			
TOTAL APPLIANCES: 074									
TEST ENGINEER SIGNATURE: LCHANTRY				TEST ENGINEER NAME: LAYTON CHANTRY					
TEST EQUIPMENT USED: MEGGER PAT120				Date: 01/06/2018					